

NOTES:

- 1. FENCE SHALL BE 6' IN HEIGHT AND SET AT TREE DRIP LINE.
- 2. FENCE MATERIALS SHALL CONSIST OF 2" MESH CHAIN LINKS SECURED TO A MINIMUM 1 1/2" DIA. STEEL OR ALUMINUM LINE POSTS.
- 3. POSTS SHALL BE SET TO A DEPTH OF NO LESS THAN 2 FEET IN NATIVE SOIL.
- 4. FENCE SHALL REMAIN IN PLACE UNTIL THE COMPLETION OF CONSTRUCTION ACTIVITIES. MOVEMENT OR REMOVAL OF FENCE REQUIRES APPROVAL BY CITY'S AUTHORIZED REPRESENTATIVE.

Tree Protection Fencing		
DRAWING NUMBER: RD-1230	DRAWN BY: SR	SCALE: N.T.S.
FILE NAME: RD-1230.DWG	APPROVED BY: NK	DATE: 4/2/14

CITY OF
WILSONVILLE
PUBLIC WORKS STANDARDS

