



NOTES:

1. EXTEND 2" NUT TO WITHIN 18" OF FINISH GRADE WHEN VALVE NUT IS DEEPER THAN 3 FEET FROM FINISHED GRADE.
2. WHERE DEPTH IS OVER 6 FEET. A SECOND PLATE WILL BE INSTALLED EQUIDISTANT BETWEEN FIRST ROCK GUARD AND 2" VALVE NUT.
3. WATERLINE DEEPER THAN 4 FEET SHALL BE APPROVED BY CITY'S AUTHORIZED REPRESENTATIVE.
4. HOT DIP GALVANIZE VALVE OPERATOR EXTENSION AFTER FABRICATION.

Valve Operator Extension

CITY OF
WILSONVILLE



DRAWING NUMBER: WT-3015

DRAWN BY: SR

SCALE: N.T.S.

FILE NAME: WT-3015.DWG

APPROVED BY: NK

DATE: 6/4/14

PUBLIC WORKS STANDARDS